

SR\_ ROOF PANEL CLIP W/  
( ) ¼ - 14 x 2" TEK 3 W/O WASHER  
PER CLIP, PER PANEL AT EACH LAP  
SECONDARY SUPPORT

¼ - 14 x 7/8" STITCH  
TEKS 2 ½" O/C AT LAP

NOTE: BUTYL SEALANT  
AND BUTYL TAPE TO RUN  
ACROSS FULL WIDTH OF  
PANELS; NOT SHOWN AT  
HIGH RIBS FOR CLARITY.

1" x 3/32" BUTYL TAPE SEALANT

SUPPORT ANGLE AND  
FASTENERS BY OTHERS  
(NOT BY IMP SUPPLIER)

SECONDARY FRAMING  
(NOT BY IMP SUPPLIER)

CONTINUOUS ½" Ø BEAD OF GUN-GRADE  
NON-SKINNING BUTYL SEALANT AT PANEL END-LAP

¼" BEAD OF BUTYL SEALANT (REFER  
TO SR ROOF PANEL JOINT DETAIL)

NOTE: REFER TO  
SECTION 13.6 ON SHEET 8  
OF 10 ON SR2 & SR3  
INSULATED ROOF PANELS  
GENERAL INSTALLATION  
GUIDE FOR ADDITIONAL  
INFORMATION.

FIELD-APPLIED ⅛" BEAD  
OF BUTYL SEALANT ON  
UNDERSIDE OF SR CLIP

FACTORY-APPLIED FOAM GASKET  
AT UNDERSIDE OF SR ROOF CLIP

ONE-PART EXPANDING  
URETHANE SEALANT BY  
OTHERS (NOT BY IMP  
SUPPLIER)

NOTE: DO NOT OVER-DRIVE FASTENERS. IF  
THE METAL AT THE EDGE OF THE PANEL IS  
DEFORMED OUT OF PLANE, THE ADJACENT  
PANEL WILL BE DIFFICULT TO ENGAGE AND  
WILL NOT SEAM. AFTER SR CLIP HAS BEEN  
INSTALLED OVER MALE LEG OF STANDING  
SEAM PANEL, PRE-CRIMP, USING (RENTED)  
½" HAND CRIMPING TOOL.

# # SR ROOF PANEL END-LAP

(SECTION VIEW)

DETAIL:	SR ROOF PANEL END-LAP
APPLICATION:	COLD-STORAGE - SR ROOF
DATE:	11/15/16
JOB NO.:	N/A
DRAWN:	MMF
SHEET:	1 OF 1

US: (888) 970-2947  
CA: (800) 265-6583 (English)  
CA: (800) 567-2582 (French)  
WWW.AWIPANELS.COM

ALL WEATHER  
INSULATED PANELS

