

SR\_ ROOF PANEL CLIP W/  
( ) 1/4 - 14 x 2" TEK 3 W/O WASHER  
PER CLIP, PER PANEL AT EACH LAP  
SECONDARY SUPPORT

1/4 - 14 x 7/8" STITCH  
TEKS 2 1/2" O/C AT LAP

NOTE: BUTYL SEALANT  
AND BUTYL TAPE TO RUN  
ACROSS FULL WIDTH OF  
PANELS; NOT SHOWN AT  
HIGH RIBS FOR CLARITY.

1" x 3/16" BUTYL TAPE SEALANT

FACTORY-APPLIED FOAM GASKET  
AT UNDERSIDE OF SR ROOF CLIP

"JC-01" JOINT COVER  
(SET TRIM IN BUTYL SEALANT)

CONTINUOUS 1/2" Ø BEAD OF  
GUN-GRADE NON-SKINNING BUTYL  
SEALANT AT PANEL END-LAP

FIELD-APPLIED 1/4" BEAD  
OF NON-SKINNING BUTYL  
SEALANT AT SR OVERLAP

FIELD-APPLIED 1/8" BEAD  
OF BUTYL SEALANT ON  
UNDERSIDE OF SR CLIP  
CONTINUOUS 1/2" Ø BEAD OF BUTYL  
SEALANT (CONNECT ENDS OF  
CAULK BEADS TO CLOSE AND BOX)

SECONDARY FRAMING  
(NOT BY IMP SUPPLIER)

NOTE: REFER TO SECTION 13.7 ON  
THE SR2 INSULATED ROOF PANELS  
GENERAL INSTALLATION GUIDE  
FOR ADDITIONAL INFORMATION.

STITCH TEK AT RIB MUST BE  
INSTALLED AFTER SEAMING

2 1/2" 2 1/2"  
TYP. TYP.

STITCH TEK AT RIB  
MUST BE INSTALLED  
AFTER SEAMING

## SECTION A-A

NOTE: DO NOT OVER-DRIVE FASTENERS. IF THE METAL AT THE EDGE OF THE  
PANEL IS DEFORMED OUT OF PLANE, THE ADJACENT PANEL WILL BE DIFFICULT TO  
ENGAGE AND WILL NOT SEAM. AFTER SR CLIP HAS BEEN INSTALLED OVER MALE  
LEG OF STANDING SEAM PANEL, PRE-CRIMP, USING 1/2" HAND CRIMPING TOOL.

## # SR ROOF PANEL ENDLAP (SECTION VIEW)

### DETAIL: ENDLAP

929 ALDRIDGE ROAD  
VACAVILLE, CA 95688  
TEL: (707) 359-2280  
FAX: (707) 359-2286  
WWW.AWIPANELS.COM

ALL WEATHER  
INSULATED PANELS



APPLICATION:  
SR ROOF, COMMERCIAL & INDUSTRIAL, COLD-STORAGE, COLD-CLIMATE  
AWIP DETAIL NUMBER:  
SRR-CICSCC-EL-002

DATE:  
01/08/20

DRAWN BY:  
MMF

SHEET:

1  
OF  
1