

"BC-03" 20 GA CHANNEL CAP W/ 14. - 13
x 1.5" TRU DP1 12" O/C. W/ BUTYL
SEALANT AT FLANGES (MARRY TO
VERTICAL SEALANT)

NOTE: REFER TO DETAIL _E FOR EDGE
METAL ASSEMBLY INFORMATION.

NOTE: BUTYL SEALANT
AT WALL JOINERY NOT
SHOWN FOR CLARITY.
ENSURE ALL SEALANTS
MARRY TO CREATE A
THERMAL ENVELOPE.

FILL VOID WITH ONE-PART
EXPANDING FOAM SEALANT
CONTINUOUS THERMAL CUT FOR
COLD STORAGE APPLICATIONS

"WC-01" PANEL CLIP W/
() 1/4 - 14 x _ HWH DP3 W/O
WASHER AT PANEL JOINT

3" MIN.

HOT-AIR WELDED _ 45 MIL
REINFORCED FLASHING
ONEDEK® THERMOPLASTIC
ROOF MEMBRANE (SEE
"ONEDEK® ROOFING MEMBRANE"
FOR ATTACHMENT OPTIONS)


12. - 24 x _ PNC DP4 W/ "RP-01"
ROOF DECK PLATE (REFER TO
RD1 FASTENING SYSTEM)

BUTYL TAPE

EAVE STRUT (NOT BY
ONEDEK® SUPPLIER)

GUTTER W/ PERIMETER EDGE METAL

(SECTION VIEW)



DETAIL: GUTTER W/ PERIMETER EDGE METAL

929 ALDRIDGE ROAD
VACAVILLE, CA 95688
TEL: (707) 359-2280
FAX: (707) 359-2286
WWW.AWIPANELS.COM

All Weather
Insulated Panels



APPLICATION:
RD1 ROOF DECK, COMMERCIAL & INDUSTRIAL, COLD-STORAGE

AWIP DETAIL NUMBER:
RDR-CICS-EG-002

DATE:
10/25/23

DRAWN BY:
MMF

SHEET:
1 OF 1

"BC-03" 20 GA CHANNEL CAP W/ 14. - 13
x 1.5" TRU DP1 12" O/C. W/ BUTYL
SEALANT AT FLANGES (MARRY TO
VERTICAL SEALANT)

POLYETHER SEALANT

CB-90 TERMINATION BAR x 10'-0"

BUTYL SEALANT

3" MIN.

HOT-AIR WELDED __ 45 MIL
REINFORCED FLASHING
ONEDEK® THERMOPLASTIC
ROOF MEMBRANE (SEE
"ONEDEK® ROOFING MEMBRANE"
FOR ATTACHMENT OPTIONS)


2-PIECE EXTRUDED
ALUM. BRACKET 1" WIDE
@ 2'-0" O/C

1 1/2" MIN. WELD (CONTINUOUS)

14. - 13 x 1.5" TRU DP1 6" O/C

#14 x 1 1/2" UNIVERSAL
FASTENER 2'-0" O/C

WR GUTTER - 7 3/4", FORMED IN
12'-0" LENGTHS W/
CONCEALED SPLICES, 6" WIDE



#E GUTTER W/ PERIMETER EDGE METAL

(SECTION VIEW)

DETAIL:

GUTTER W/ PERIMETER EDGE METAL, WR 7 3/4"

APPLICATION:

RD1 ROOF DECK, COMMERCIAL & INDUSTRIAL, COLD-STORAGE

AWIP DETAIL NUMBER:

RDR-CICS-EG-002

929 ALDRIDGE ROAD
VACAVILLE, CA 95688
TEL: (707) 359-2280
FAX: (707) 359-2286
WWW.AWIPANELS.COM

All Weather
Insulated Panels



SHEET:

DATE:

11/17/23

DRAWN BY:

MMF

1

OF 1