

- Insulated roof deck is a single component functioning as the deck, air and vapor barrier, insulation, and coverboard while providing a uniform walkable surface ideal for membrane installation
- Single point of accountability from the roof structure (decking, insulation, membrane and edge metal) out for weather tightness warranties and components
- Coil coated interior skin eliminates the need for field painting of the decking. Interior can be painted virtually any color



Product Specifications								
Profile	Exterior		Smooth Flat					
	Interior		Embossed, Lig	ghtly Planked, N	1esa Rib			
Exterior Face Skin	26 Gauge G90 Galvanized or AZ50 Galvalume. 24 and 22 Gauge optional							
Interior Face Skin	26 Gauge G90 Galvanized or AZ50 Galvalume. 24 and 22 Gauge optional, 26 304 2B Stainless Steel							
Slope Requirements	Minimum 1/4:12 Slope Maximum 1:12 TPO, 2:12 PVC							
Panel Module**	40"[1016mm]							
Lengths**	Minimum: 8'[2.44m], Maximum: 50'[15.24m]							
Side Lap	Double Tongue and Groove							
GWP±	5.7 to 10.6 Lb CO <sub>2</sub> eq/ft² [27.6 to 51.9 kg CO <sub>2</sub> eq/m²]							
Thermal Performance <sup>†</sup>								
Thickness	2"[51mm]	2.5"[64mm]	3"[76mm]	4"[102mm]	5"[127mm]	6"[152mm]	8"[203mm]	
R-Value @ 75°F mean (°F·ft2·h/BTU)	14	18	21	28	36	43	57	
U-Value @ 75°F mean (BTU/°F·ft2·h)	0.069	0.056	0.046	0.035	0.028	0.023	0.017	

24

0.041

32

0.031

41

0.024

R-Value @ 35°F mean (°F·ft2·h/BTU)

U-Value @ 35°F mean (BTU/°F·ft2·h)

16

0.061

20

0.049



65

0.015

49

0.020

Contact AWIP for Custom Sizes

<sup>†</sup> Thermal values as tested per ASTM C518 ± Per EPD based on TRACI method from cradle to gate(A1-A3). Lower range based on 2" 26/26 gauge panel. Higher limit based on 6" 22/22 gauge panel. Not all profiles are available in these specific configurations, contact AWIP for more information.

## **Testing & Approvals**

Category	Test	Test Title	Results		
Fire	FM 4880	FM Class 1 Fire Rating	Pass		
	ASTM E108	Roof Coverings Fire Test	Pass with Approved Assemblies		
	ASTM E84	Surface Burning Characteristics of Building Materials	Flame Spread Index: 25 or less Smoke Developed Index: 450 or less		
	CAN/ULC S126	Fire Spread Under Roof	Pass		
	CAN/ULC S138	Room Corner Test	Pass		
Water Penetration	ASTM E1646	Standard Test Method for Water Penetration of Exterior Metal Roof Panel Systems by Uniform Static Air Pressure Difference	20 PSF		
Air Infiltration	ASTM E1680	Standard Test Method for Rate of Air Leakage Through Exterior Metal Roof Panel Systems	< 0.02 cfm/ft2 at 12 PSF		
Structural	ASTM E72	Standard Test Methods of Conducting Strength Tests of Panels for Building Construction	See Span Tables		
	ASTM E1592	Structural Performance for Sheet Metal and Sidings Systems by Uniform Static Air Pressure Difference	See Span Tables		
	FM 4470	FM Class 1 Single Ply Roof	Pass		
	FM 4471	FM Class 1 Panel Roof	Pass		
	AISI S907	Test Standard for Determining the Strength and Stiffness of Cold-Formed Steel Diaphragms	Available		
Thermal	ASTM C518	Steady-State Thermal Transmission Properties by Means of the Heat-Flow Meter Apparatus	Nominal R-value of 7.2 [hr·ft2.°F/Btu] per inch at 75°F mean temperature and 8.2 [hr·ft2.°F/Btu] per inch at 35°F mean temperature		
Code Approval	IAPMO	International Building Code	Evaluation Report 529		



Additional Note: Consult your AWIP Technical Services Representative or RoofNav for FM Approved Assemblies



Scan for the most current product information`

1 (888) 970-AWIP (2947) awipanels.com sales@awipanels.com

